



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

18G2058

Gannett Fleming, Inc.

Project Name: BASD - Summit Elementary

Eric Buzza
Foster Plaza III, Suite 200, 601 Holiday Drive
Pittsburgh, PA 15220

Project / PO Number: N/A
Received: 07/19/2018
Reported: 07/25/2018

Project Special Information

5100445

Analytical Testing Parameters

Table with client sample details: Client Sample ID: Kitchen Sink, Sample Matrix: Drinking Water, Lab Sample ID: 18G2058-01, Collected By: Eric Buzza, Collection Date: 07/19/2018 8:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Method: EPA 200.8, Rv. 5.4. Rows for Copper and Lead.

Table with client sample details: Client Sample ID: Room 7, Sample Matrix: Drinking Water, Lab Sample ID: 18G2058-02, Collected By: Eric Buzza, Collection Date: 07/19/2018 8:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Method: EPA 200.8, Rv. 5.4. Rows for Copper and Lead.

Table with client sample details: Client Sample ID: Room 17, Sample Matrix: Drinking Water, Lab Sample ID: 18G2058-03, Collected By: Eric Buzza, Collection Date: 07/19/2018 8:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Method: EPA 200.8, Rv. 5.4. Rows for Copper and Lead.



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

18G2058

<b>Client Sample ID:</b> Faculty Room	<b>Collected By:</b> Eric Buzza
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 07/19/2018 8:50
<b>Lab Sample ID:</b> 18G2058-04	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Copper	0.184	1.30 AL	0.0010	mg/L		07/23/18 1707	07/23/18 1900	DLO
Lead	<0.0010	0.0150 AL	0.0010	mg/L		07/23/18 1707	07/23/18 1900	DLO

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL:** US EPA Action Level
- RL:** Reporting Limit
- SMCL:** US EPA Secondary Maximum Contaminant Level

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 68-04413	Pennsylvania Department of Environmental Protection
Microbac Laboratories, Inc. - Erie PA DEP# 25-00067	PA Department of Environmental Protection PADEP Accreditation by Rule

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Carolyn Vollenline  
Project Manager  
Reported: 07/25/2018 19:33



CHAIN OF CUSTODY

Put bar code here

Microbac Erie Division  
1962 Wager Road  
Erie, PA 16509  
814.825.8533  
eriemm@microbac.com

Page \_\_\_ of \_\_\_



\*18G2058\*

Gannett Fleming, Inc.

Client/Company Name: 8450 GF		Contact Name: Eric Buzza	
Address: Poststar Plaza 8 Suite 400 730 1st Day Dr		Bill To/PO#:	
City/State/Zip: Pittsburgh PA 15720		Potential Hazards: Non-Hazard <input type="checkbox"/> Hazard <input type="checkbox"/> Radioactive <input type="checkbox"/>	
Phone: 412 992 5575	Email/Fax: edwz20@fnet.com	Disposal: Dispose of <input type="checkbox"/> Return <input type="checkbox"/> Retain <input type="checkbox"/>	
Project Name/ID: Summit Element (fwd)		Compliance Sample: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
Sampled By: Eric Buzza		Due Date:	
Shipped By:		Tracking #:	
Type Code: G-Grab C-Composite		Comp. Start:	
Matrix Code: DW-Potable water WW-Nonpotable water SS-Soil/Sludge F-Food S-Swab O-Other		Comp. Stop:	
Sample Identification		Preservatives	
	Date Taken	Time Taken	Type
Kitchen Sink	7/19/18	810	G C
Room 7		825	
Room 17		835	
Faculty Room		850	
Instructions/Comments:			
Lead + Copper			
Relinquished By: Eric Buzza		Date/Time: 7/19/18 1230	
Received By: Julie Quail		Date/Time: 7.19.18 1230	
Temp: 24.4°C		Intact: Y N	