



DRAFT REPORT

EXCEEDANCE NOTICE

D811269

Microbac Laboratories, Inc. - Erie

Project Name: 1810879

Carolyn Vollentine
1962 Wager Road
Erie, PA 16509

Project / PO Number: N/A
Received: 09/11/2018
Reported: 09/17/2018

Project Special Information

5100445

Analytical Testing Parameters

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (1810879-03 (Cafe A Hand Sink), Drinking Water, D811269-03, Eric Buzza, 09/07/2018 7:53)

Table with 9 columns: Metals, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0251, 0.0150 AL, 0.0010, mg/L, 09/17/18 0908, 09/17/18 0956, DAY

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (1810879-05 (Room 115 Sink), Drinking Water, D811269-05, Eric Buzza, 09/07/2018 7:58)

Table with 9 columns: Metals, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.109, 0.0150 AL, 0.0010, mg/L, 09/17/18 0908, 09/17/18 1000, DAY


Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (1810879-12 (Room 224), Drinking Water, D811269-12, Eric Buzza, 09/07/2018 7:40)

Table with 9 columns: Metals, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0164, 0.0150 AL, 0.0010, mg/L, 09/17/18 0908, 09/17/18 1018, DAY

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Laboratory

DAY: Microbac Laboratories, Inc. - Dayville

 **MICROBAC**[®]
DRAFT REPORT
CERTIFICATE OF ANALYSIS
D811269

Definitions

AL: US EPA Action Level
MCL: US EPA Maximum Contaminant Level
RL: Reporting Limit
SMCL: US EPA Secondary Maximum Contaminant Level
