



Microbac Laboratories Inc., Pittsburgh Division

## CERTIFICATE OF ANALYSIS

0123556

**GANNETT FLEMING, INC.**

ERIC BUZZA  
FOSTER PLAZA III- SUITE 200 601 HOLIDAY DRIVE  
PITTSBURGH, PA 15220

**Project Name: BASD High School**

Project / PO Number: N/A  
Received: 12/22/2020  
Reported: 12/30/2020

### Analytical Testing Parameters

**Client Sample ID:** NWSAS Kitchen Sink 1st drain

**Sample Matrix:** Drinking Water

**Lab Sample ID:** 0123556-01

**Collected By:** ERIC BUZZA

**Collection Date:** 12/22/2020 10:25

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	83.9	15.0	0.400	ug/L		12/30/20 1410	12/30/20 1410	EMB

**Client Sample ID:** NWSAS Kitchen Sink 2 min flush

**Sample Matrix:** Drinking Water

**Lab Sample ID:** 0123556-02

**Collected By:** ERIC BUZZA

**Collection Date:** 12/22/2020 10:27

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.931	15.0	0.400	ug/L		12/30/20 1412	12/30/20 1412	EMB

**Client Sample ID:** NWSAS Sink 1st Drain

**Sample Matrix:** Drinking Water

**Lab Sample ID:** 0123556-03

**Collected By:** ERIC BUZZA

**Collection Date:** 12/22/2020 10:30

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	8.72	15.0	0.400	ug/L		12/30/20 1414	12/30/20 1414	EMB

**Client Sample ID:** NWSAS Sink 1 min Flush

**Sample Matrix:** Drinking Water

**Lab Sample ID:** 0123556-04

**Collected By:** ERIC BUZZA

**Collection Date:** 12/22/2020 10:32

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.514	15.0	0.400	ug/L		12/30/20 1419	12/30/20 1419	EMB

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

### Definitions

**RL:** Reporting Limit

**ug/L:** Micrograms per Liter

Microbac Laboratories, Inc.

100 Marshall Drive | Warrendale, PA 15086 | 724-772-0610 p | www.microbac.com

Page 1 of 3



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

0123556

**Project Requested Certification(s)**

Microbac Laboratories Inc., Pittsburgh Division  
02-00257

PA Department of Environmental Protection  
PADEP Accreditation by Rule

---

**Report Comments**

*Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.*

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

**Reviewed and Approved By:**

Carolyn Vollentine  
Service Center Manager  
Reported: 12/30/2020 16:33

Microbac Laboratories, Inc.


100 Marshall Drive | Warrendale, PA 15086 | 724-772-0610 p | [www.microbac.com](http://www.microbac.com)

Page 2 of 3



814.825.8533  
[erimm@microbac.com](mailto:erimm@microbac.com)

Page \_\_\_\_ of \_\_\_\_



0	1	2	3	5	5	5	6
---	---	---	---	---	---	---	---

GANNETT FLEMING, INC.

PM: Carolyn Vollentine

Client /Company Name: BASO GF		Contact Name: Eric Buza	
Address: Foster Plaza Suite 400 730 Highland		Bill To/PO#: Sano	
City/State/Zip: Pittsburgh PA 15120			
Phone: 412 922 5575		Email/Fax: ebuza@gsnet.com	
Project Name/ID: BASO High School		Potential Hazards: Non-Hazard <input checked="" type="checkbox"/> Hazard <input type="checkbox"/> Radioactive <input type="checkbox"/>	
Sampled By: Eric Buza		Disposal: Dispose of <input checked="" type="checkbox"/> Return <input type="checkbox"/> Retain <input type="checkbox"/>	
Shipped By:		Compliance Sample: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
Tracking #:		State:	
Comp. Start:		Monitoring Period:	
Comp. Stop:		Preservatives	
Type Code: G-Grab C-Composite	Matrix Code: DW-Potable water WW-Nonpotable water SS-Soil/Sludge F-Food S-Swab O-Other	Type	Tot. #
Sample Identification	Date Taken	G C	Cont.
Nurses Kitchen Sink 1st Floor	12/22/20	1025	1
Nurses Kitchen Sink 2nd Floor	1027	1	1
Nurses Sink 1st Floor	1030	1	1
Nurses Sink 2nd Floor	1032	1	1
Instructions/Comments:			
Relinquished By: Eric Buza	Date/Time: 12/22/20 11:25	Received By:	
Relinquished By:	Date/Time:	Received By:	
Relinquished By:	Date/Time:	Received By:	
Relinquished By:	Date/Time:	Received By:	

QC270 V6