



*Excellence Delivered **As Promised***

March 28, 2017

Mr. Brian Slamecka
Butler Area School District
110 Campus Lane
Butler, PA 16001

Subject: *Butler Area School District
School District Facilities Lead and Copper Testing*

Dear Mr. Slamecka:

Gannett Fleming is pleased to report that the results of the Lead and Copper test results of drinking water fountains and plumbing fixtures at the Butler Area School District facilities have been received. The following facilities were tested:

1. Intermediate School
2. Senior High School
3. Center Avenue Elementary
4. Broad Street Elementary
5. Emily Britton Elementary
6. Middle School
7. Connoquenessing Elementary
8. Center Township Elementary
9. McQuiston Elementary
10. Northwest Elementary
11. Administration Building

These facilities receive their water from Pennsylvania American Water Company which is the public water supplier for the Butler area. Sampling was conducted of every drinking fountain in each of the aforementioned buildings, as well as any other fixture that is used as sources of drinking water. Gannett Fleming personnel conducted the sampling following USEPA / PADEP requirements. These requirements include collecting "first draw" samples. That is, sampling of the fixtures was conducted after they had been allowed to sit stagnant overnight. Sampling was conducted prior to the start of the buildings being occupied for the school day. Each fixture was tagged and taken out of service so that it was not mistakenly used prior to the collection of the first draw sample.

A total of 196 samples were collected from the 11 buildings. Of those samples, one (1), the fixture in the Conference Room of the Intermediate School, exceeded the PaDEP's 0.015 mg/L Action Level for Lead; and, one (1), the drinking fountain in Room 11 at the Center Avenue Elementary School, exceeded the PaDEP's 1.3 mg/L Action Level for Copper. See attached summary of the sampling results. It is our understanding that the School District removed that fixture from service immediately upon notification of the Action Level exceedance.

Gannett Fleming, Inc.

Foster Plaza 8 • Suite 400 • 730 Holiday Drive • Pittsburgh, PA 15220

t: 412-922-5575 • f: 412-922-3717

www.gannettfleming.com

Mr. Brian Slamecka
Page 2
March 28, 2017

Please find attached the summary and laboratory reports for these testing events. Gannett Fleming would like to thank the School District's administrative and maintenance staff for their assistance in completing this project.

Should you have any questions, or desire any additional information, please do not hesitate to contact us.

Sincerely,

GANNETT FLEMING, INC.



DANIEL J. GONCZ, P.E.
Vice President

Enclosures

Butler Area School District
 Facilities Lead and Copper Testing Results
 March 28, 2017

Facility	Location	Sample Date	Parameter	Result (mg/L) Above AL is Highlighted	PaDEP AL Designation (mg/l)
Intermediate School	Office Men	2/20/2017	Lead	<0.001	0.015
Intermediate School	Office Men	2/20/2017	Copper	0.113	1.3
Intermediate School	Office Women	2/20/2017	Lead	<0.001	0.015
Intermediate School	Office Women	2/20/2017	Copper	0.158	1.3
Intermediate School	Security Desk	2/20/2017	Lead	0.002	0.015
Intermediate School	Security Desk	2/20/2017	Copper	0.285	1.3
Intermediate School	Nurse's Desk	2/20/2017	Lead	<0.001	0.015
Intermediate School	Nurse's Desk	2/20/2017	Copper	0.166	1.3
Intermediate School	Aux Gym	2/20/2017	Lead	<0.001	0.015
Intermediate School	Aux Gym	2/20/2017	Copper	0.081	1.3
Intermediate School	Pool Left	2/20/2017	Lead	<0.001	0.015
Intermediate School	Pool Left	2/20/2017	Copper	0.080	1.3
Intermediate School	Pool Right	2/20/2017	Lead	0.001	0.015
Intermediate School	Pool Right	2/20/2017	Copper	0.090	1.3
Intermediate School	Weight Room	2/20/2017	Lead	<0.001	0.015
Intermediate School	Weight Room	2/20/2017	Copper	0.238	1.3
Intermediate School	Girl's Lock Lft	2/20/2017	Lead	<0.001	0.015
Intermediate School	Girl's Lock Lft	2/20/2017	Copper	0.066	1.3
Intermediate School	Girl's Lock Rgt	2/20/2017	Lead	<0.001	0.015
Intermediate School	Girl's Lock Rgt	2/20/2017	Copper	0.056	1.3
Intermediate School	Training Room	2/20/2017	Lead	<0.001	0.015
Intermediate School	Training Room	2/20/2017	Copper	0.112	1.3
Intermediate School	Training Room Ice	2/20/2017	Lead	<0.001	0.015
Intermediate School	Training Room Ice	2/20/2017	Copper	<0.010	1.3
Intermediate School	JROTC Women	2/20/2017	Lead	<0.001	0.015
Intermediate School	JROTC Women	2/20/2017	Copper	0.214	1.3
Intermediate School	Café B Front	2/20/2017	Lead	<0.001	0.015
Intermediate School	Café B Front	2/20/2017	Copper	0.235	1.3
Intermediate School	Café B Back	2/20/2017	Lead	<0.001	0.015
Intermediate School	Café B Back	2/20/2017	Copper	0.078	1.3
Intermediate School	140 L	2/20/2017	Lead	<0.001	0.015
Intermediate School	140 L	2/20/2017	Copper	0.100	1.3
Intermediate School	140 R	2/20/2017	Lead	<0.001	0.015
Intermediate School	140 R	2/20/2017	Copper	0.104	1.3
Intermediate School	126	2/20/2017	Lead	<0.001	0.015
Intermediate School	126	2/20/2017	Copper	0.089	1.3
Intermediate School	124	2/20/2017	Lead	<0.001	0.015
Intermediate School	124	2/20/2017	Copper	0.208	1.3
Intermediate School	AV Left	2/20/2017	Lead	0.001	0.015
Intermediate School	AV Left	2/20/2017	Copper	0.154	1.3
Intermediate School	AV Right	2/20/2017	Lead	0.001	0.015
Intermediate School	AV Right	2/20/2017	Copper	0.131	1.3
Intermediate School	Café A Front	2/20/2017	Lead	0.001	0.015
Intermediate School	Café A Front	2/20/2017	Copper	0.181	1.3
Intermediate School	Café A Back	2/20/2017	Lead	0.001	0.015
Intermediate School	Café A Back	2/20/2017	Copper	0.130	1.3
Intermediate School	Café A Sink	2/20/2017	Lead	0.002	0.015
Intermediate School	Café A Sink	2/20/2017	Copper	0.155	1.3
Intermediate School	116	2/20/2017	Lead	<0.001	0.015

Facility	Location	Sample Date	Parameter	Result (mg/L) Above AL is Highlighted	PaDEP AL Designation (mg/l)
Intermediate School	116	2/20/2017	Copper	0.123	1.3
Intermediate School	115	2/20/2017	Lead	0.001	0.015
Intermediate School	115	2/20/2017	Copper	0.101	1.3
Intermediate School	108	2/20/2017	Lead	<0.001	0.015
Intermediate School	108	2/20/2017	Copper	0.201	1.3
Intermediate School	Wood Shop	2/20/2017	Lead	<0.001	0.015
Intermediate School	Wood Shop	2/20/2017	Copper	0.342	1.3
Intermediate School	103	2/20/2017	Lead	0.002	0.015
Intermediate School	103	2/20/2017	Copper	0.142	1.3
Intermediate School	Stucco Store Lft	2/20/2017	Lead	0.002	0.015
Intermediate School	Stucco Store Lft	2/20/2017	Copper	0.129	1.3
Intermediate School	Stucco Store Rgt	2/20/2017	Lead	0.001	0.015
Intermediate School	Stucco Store Rgt	2/20/2017	Copper	0.120	1.3
Intermediate School	Lounge W Bath	2/20/2017	Lead	0.004	0.015
Intermediate School	Lounge W Bath	2/20/2017	Copper	0.232	1.3
Intermediate School	Lounge M Bath	2/20/2017	Lead	0.003	0.015
Intermediate School	Lounge M Bath	2/20/2017	Copper	0.211	1.3
Intermediate School	Lounge Sink	2/20/2017	Lead	<0.001	0.015
Intermediate School	Lounge Sink	2/20/2017	Copper	0.111	1.3
Intermediate School	Psy K	2/20/2017	Lead	0.005	0.015
Intermediate School	Psy K	2/20/2017	Copper	0.142	1.3
Intermediate School	Conference	2/20/2017	Lead	0.018	0.015
Intermediate School	Conference	2/20/2017	Copper	0.372	1.3
Intermediate School	JROTC 1	2/20/2017	Lead	<0.001	0.015
Intermediate School	JROTC 1	2/20/2017	Copper	0.069	1.3
Intermediate School	JROTC 2	2/20/2017	Lead	<0.001	0.015
Intermediate School	JROTC 2	2/20/2017	Copper	0.085	1.3
Intermediate School	235	2/20/2017	Lead	<0.001	0.015
Intermediate School	235	2/20/2017	Copper	0.089	1.3
Intermediate School	Café D Front	2/20/2017	Lead	0.002	0.015
Intermediate School	Café D Front	2/20/2017	Copper	0.140	1.3
Intermediate School	Café D Back	2/20/2017	Lead	<0.001	0.015
Intermediate School	Café D Back	2/20/2017	Copper	0.077	1.3
Intermediate School	207	2/20/2017	Lead	<0.001	0.015
Intermediate School	207	2/20/2017	Copper	0.086	1.3
Intermediate School	203	2/20/2017	Lead	0.001	0.015
Intermediate School	203	2/20/2017	Copper	0.210	1.3
Intermediate School	English WRR	2/20/2017	Lead	<0.001	0.015
Intermediate School	English WRR	2/20/2017	Copper	0.047	1.3
Intermediate School	English MRR	2/20/2017	Lead	<0.001	0.015
Intermediate School	English MRR	2/20/2017	Copper	0.065	1.3
Intermediate School	Café C Front	2/20/2017	Lead	0.006	0.015
Intermediate School	Café C Front	2/20/2017	Copper	0.175	1.3
Intermediate School	Café C Back	2/20/2017	Lead	<0.001	0.015
Intermediate School	Café C Back	2/20/2017	Copper	0.092	1.3
Intermediate School	Speech	2/20/2017	Lead	0.001	0.015
Intermediate School	Speech	2/20/2017	Copper	0.109	1.3
Intermediate School	252	2/20/2017	Lead	0.003	0.015
Intermediate School	252	2/20/2017	Copper	0.144	1.3
Intermediate School	222	2/20/2017	Lead	0.002	0.015
Intermediate School	222	2/20/2017	Copper	0.138	1.3
Intermediate School	241	2/20/2017	Lead	<0.001	0.015

Facility	Location	Sample Date	Parameter	Result (mg/L) Above AL is Highlighted	PaDEP AL Designation (mg/l)
Intermediate School	241	2/20/2017	Copper	0.063	1.3
Intermediate School	246	2/20/2017	Lead	<0.001	0.015
Intermediate School	246	2/20/2017	Copper	0.076	1.3
Senior High School	Maint Garage	2/20/2017	Lead	0.005	0.015
Senior High School	Maint Garage	2/20/2017	Copper	0.176	1.3
Senior High School	Maint Store Rm	2/20/2017	Lead	<0.001	0.015
Senior High School	Maint Store Rm	2/20/2017	Copper	0.132	1.3
Senior High School	Auditorium 1	2/20/2017	Lead	0.007	0.015
Senior High School	Auditorium 1	2/20/2017	Copper	0.634	1.3
Senior High School	Auditorium 2	2/20/2017	Lead	<0.001	0.015
Senior High School	Auditorium 2	2/20/2017	Copper	0.338	1.3
Senior High School	Auditorium 3	2/20/2017	Lead	0.007	0.015
Senior High School	Auditorium 3	2/20/2017	Copper	0.234	1.3
Senior High School	Auditorium 4	2/20/2017	Lead	0.002	0.015
Senior High School	Autitoroum 4	2/20/2017	Copper	0.069	1.3
Senior High School	Auditorium 5	2/20/2017	Lead	<0.001	0.015
Senior High School	Auditorium 5	2/20/2017	Copper	0.103	1.3
Senior High School	Food Service Fount	2/20/2017	Lead	0.002	0.015
Senior High School	Food Service Fount	2/20/2017	Copper	0.175	1.3
Senior High School	Food Service Sink	2/20/2017	Lead	<0.001	0.015
Senior High School	Food Service Sink	2/20/2017	Copper	0.072	1.3
Senior High School	Café Fount 1	2/20/2017	Lead	0.004	0.015
Senior High School	Café Fount 1	2/20/2017	Copper	0.849	1.3
Senior High School	Café Fount 2	2/20/2017	Lead	0.002	0.015
Senior High School	Café Fount 2	2/20/2017	Copper	0.111	1.3
Senior High School	Cage Fount 3	2/20/2017	Lead	0.002	0.015
Senior High School	Café Fount 3	2/20/2017	Copper	0.159	1.3
Senior High School	Café Fount 4	2/20/2017	Lead	<0.001	0.015
Senior High School	Café Fount 4	2/20/2017	Copper	0.166	1.3
Senior High School	Nurses Off Sink	2/20/2017	Lead	<0.001	0.015
Senior High School	Nurses Off Sink	2/20/2017	Copper	0.305	1.3
Senior High School	SHS Off Sink	2/20/2017	Lead	0.003	0.015
Senior High School	SHS Off Sink	2/20/2017	Copper	0.237	1.3
Senior High School	100-1 Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	100-1 Fount	2/20/2017	Copper	0.206	1.3
Senior High School	100-2 Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	100-2 Fount	2/20/2017	Copper	0.310	1.3
Senior High School	Cons Serv Sink	2/20/2017	Lead	<0.001	0.015
Senior High School	Cons Serv Sink	2/20/2017	Copper	0.192	1.3
Senior High School	200-1 Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	200-1 Fount	2/20/2017	Copper	0.182	1.3
Senior High School	300-1 Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	300-1 Fount	2/20/2017	Copper	0.431	1.3
Senior High School	300-2 Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	300-2 Fount	2/20/2017	Copper	0.166	1.3
Senior High School	306 Sink	2/20/2017	Lead	<0.001	0.015
Senior High School	306 Sink	2/20/2017	Copper	0.286	1.3
Senior High School	200-2 Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	200-2 Fount	2/20/2017	Copper	0.411	1.3
Senior High School	400-1 Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	400-1 Fount	2/20/2017	Copper	0.357	1.3
Senior High School	400-2 Fount	2/20/2017	Lead	0.003	0.015

Facility	Location	Sample Date	Parameter	Result (mg/L) Above AL is Highlighted	PaDEP AL Designation (mg/l)
Senior High School	400-2 Fount	2/20/2017	Copper	0.536	1.3
Senior High School	400-3 Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	400-3 Fount	2/20/2017	Copper	0.426	1.3
Senior High School	400-4 Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	400-4 Fount	2/20/2017	Copper	0.368	1.3
Senior High School	Annex Fount 1	2/20/2017	Lead	<0.001	0.015
Senior High School	Annex Fount 1	2/20/2017	Copper	0.272	1.3
Senior High School	Annex Trn Rm Sink	2/20/2017	Lead	0.004	0.015
Senior High School	Annex Trn Rm Sink	2/20/2017	Copper	0.242	1.3
Senior High School	Annex Trn Rm Ice	2/20/2017	Lead	<0.001	0.015
Senior High School	Annex Trn Rm Ice	2/20/2017	Copper	<0.010	1.3
Senior High School	Annex Wgt Rm Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	Annex Wgt Rm Fount	2/20/2017	Copper	0.230	1.3
Senior High School	Annex Lower Flr Lock Rm Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	Annex Lower Flr Lock Rm Fount	2/20/2017	Copper	0.129	1.3
Senior High School	Gym Fountain 1	2/20/2017	Lead	<0.001	0.015
Senior High School	Gym Fountain 1	2/20/2017	Copper	0.127	1.3
Senior High School	Gym Lobby Fount 1	2/20/2017	Lead	<0.001	0.015
Senior High School	Gym Lobby Fount 1	2/20/2017	Copper	0.351	1.3
Senior High School	Gym Lobby Fount 2	2/20/2017	Lead	<0.001	0.015
Senior High School	Gym Lobby Fount 2	2/20/2017	Copper	0.130	1.3
Senior High School	Gym Rear Hall Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	Gym Rear Hall Fount	2/20/2017	Copper	0.348	1.3
Senior High School	Boys Vars Lock Rm Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	Boys Vars Lock Rm Fount	2/20/2017	Copper	0.099	1.3
Senior High School	Swim Pool Fount	2/20/2017	Lead	0.002	0.015
Senior High School	Swim Pool Fount	2/20/2017	Copper	0.131	1.3
Senior High School	Boys Main Lock Rm Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	Boys Main Lock Rm Fount	2/20/2017	Copper	0.154	1.3
Senior High School	Gym Train Rm Sink	2/20/2017	Lead	<0.001	0.015
Senior High School	Gym Train Rm Sink	2/20/2017	Copper	0.103	1.3
Senior High School	Gym Train Rm Ice	2/20/2017	Lead	<0.001	0.015
Senior High School	Gym Train Rm Ice	2/20/2017	Copper	<0.010	1.3
Senior High School	Gym Weight Rm Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	Gym Weight Rm Fount	2/20/2017	Copper	0.121	1.3
Senior High School	Gym Main Lock Fount	2/20/2017	Lead	<0.001	0.015
Senior High School	Gym Main Lock Fount	2/20/2017	Copper	0.132	1.3
Center Ave Elementary	Nurses Rest Rm Sink	2/20/2017	Lead	<0.001	0.015
Center Ave Elementary	Nurses Rest Rm Sink	2/20/2017	Copper	0.231	1.3
Center Ave Elementary	Gym Boys Rest Rm Fount 1	2/20/2017	Lead	<0.001	0.015
Center Ave Elementary	Gym Boys Rest Rm Fount 1	2/20/2017	Copper	0.182	1.3
Center Ave Elementary	Gym Boys Rest Rm Fount 2	2/20/2017	Lead	<0.001	0.015

Facility	Location	Sample Date	Parameter	Result (mg/L) Above AL is Highlighted	PaDEP AL Designation (mg/l)
Center Ave Elementary	Gym Boys Rest Rm Fount 2	2/20/2017	Copper	0.603	1.3
Center Ave Elementary	Food Service Sink	2/20/2017	Lead	<0.001	0.015
Center Ave Elementary	Food Service Sink	2/20/2017	Copper	0.581	1.3
Center Ave Elementary	Faculty Lounge Sink	2/20/2017	Lead	<0.001	0.015
Center Ave Elementary	Faculty Lounge Sink	2/20/2017	Copper	0.317	1.3
Center Ave Elementary	Rm 11 Fountain 1	2/20/2017	Lead	<0.001	0.015
Center Ave Elementary	Rm 11 Fountain 1	2/20/2017	Copper	1.510	1.3
Center Ave Elementary	Rm 11 Fountain 2	2/20/2017	Lead	<0.001	0.015
Center Ave Elementary	Rm 11 Fountain 2	2/20/2017	Copper	0.562	1.3
Broad Street Elementary	Nurse's Sink	2/22/2017	Lead	<0.001	0.015
Broad Street Elementary	Nurse's Sink	2/22/2017	Copper	0.332	1.3
Broad Street Elementary	Faculty Lounge Sink	2/22/2017	Lead	<0.001	0.015
Broad Street Elementary	Faculty Lounge Sink	2/22/2017	Copper	0.296	1.3
Broad Street Elementary	Food Service Sink	2/22/2017	Lead	<0.001	0.015
Broad Street Elementary	Food Service Sink	2/22/2017	Copper	0.472	1.3
Broad Street Elementary	Gym Left Fountain	2/22/2017	Lead	<0.001	0.015
Broad Street Elementary	Gym Left Fountain	2/22/2017	Copper	0.254	1.3
Broad Street Elementary	Gym Right Fountain	2/22/2017	Lead	<0.001	0.015
Broad Street Elementary	Gym Right Fountain	2/22/2017	Copper	0.444	1.3
Broad Street Elementary	Main Entrance Lft	2/22/2017	Lead	<0.001	0.015
Broad Street Elementary	Main Entrance Lft	2/22/2017	Lead	0.169	0.015
Broad Street Elementary	Main Entrance Rgt	2/22/2017	Lead	<0.001	0.015
Broad Street Elementary	Main Entrance Rgt	2/22/2017	Copper	0.265	1.3
Broad Street Elementary	Computer Lab Left	2/22/2017	Lead	<0.001	0.015
Broad Street Elementary	Computer Lab Left	2/22/2017	Copper	0.175	1.3
Broad Street Elementary	Computer Lab Right	2/22/2017	Lead	<0.001	0.015
Broad Street Elementary	Computer Lab Right	2/22/2017	Copper	0.253	1.3
Broad Street Elementary	Rm 22 Left	2/22/2017	Lead	<0.001	0.015
Broad Street Elementary	Rm 22 Left	2/22/2017	Copper	0.202	1.3
Broad Street Elementary	Rm 22 Right	2/22/2017	Lead	<0.001	0.015
Broad Street Elementary	Rm 22 Right	2/22/2017	Copper	0.303	1.3
Emily Britton Elementary	1st Floor MP Room	2/22/2017	Lead	<0.001	0.015
Emily Britton Elementary	1st Floor MP Room	2/22/2017	Copper	0.273	1.3
Emily Britton Elementary	Food Service Sink	2/22/2017	Lead	<0.001	0.015
Emily Britton Elementary	Food Service Sink	2/22/2017	Copper	0.185	1.3
Emily Britton Elementary	Faculty Room	2/22/2017	Lead	<0.001	0.015
Emily Britton Elementary	Faculty Room	2/22/2017	Copper	0.271	1.3
Emily Britton Elementary	Rm 9 Fountain Low	2/22/2017	Lead	<0.001	0.015
Emily Britton Elementary	Rm 9 Fountain Low	2/22/2017	Copper	0.166	1.3
Emily Britton Elementary	Rm 9 Fountain High	2/22/2017	Lead	<0.001	0.015
Emily Britton Elementary	Rm 9 Fountain High	2/22/2017	Copper	0.214	1.3
Emily Britton Elementary	Rm 17 Fountain Low	2/22/2017	Lead	<0.001	0.015
Emily Britton Elementary	Rm 17 Fountain Low	2/22/2017	Copper	0.159	1.3
Emily Britton Elementary	Rm 17 Fountain High	2/22/2017	Lead	<0.001	0.015
Emily Britton Elementary	Rm 17 Fountain High	2/22/2017	Copper	0.226	1.3
Emily Britton Elementary	Nurse's Office Sink	2/22/2017	Lead	<0.001	0.015
Emily Britton Elementary	Nurse's Office Sink	2/22/2017	Copper	0.342	1.3
Middle School	Nurse's Office	2/22/2017	Lead	<0.001	0.015
Middle School	Nurse's Office	2/22/2017	Copper	0.214	1.3
Middle School	Fitness Rm Fountain	2/22/2017	Lead	<0.001	0.015
Middle School	Fitness Rm Fountain	2/22/2017	Copper	0.256	1.3

Facility	Location	Sample Date	Parameter	Result (mg/L) AL is Highlighted	Above PaDEP AL Designation (mg/l)
Middle School	Rm 104 Fountain	2/22/2017	Lead	<0.001	0.015
Middle School	Rm 104 Fountain	2/22/2017	Copper	0.311	1.3
Middle School	Rm 114 Fountain	2/22/2017	Lead	<0.001	0.015
Middle School	Rm 114 Fountain	2/22/2017	Copper	0.149	1.3
Middle School	Rm 147 Fountain	2/22/2017	Lead	<0.001	0.015
Middle School	Rm 147 Fountain	2/22/2017	Copper	0.269	1.3
Middle School	Rm 140 Fountain	2/22/2017	Lead	<0.001	0.015
Middle School	Rm 140 Fountain	2/22/2017	Copper	0.249	1.3
Middle School	Food Service Sink	2/22/2017	Lead	<0.001	0.015
Middle School	Food Service Sink	2/22/2017	Copper	0.236	1.3
Middle School	Faculty Caf� Sink	2/22/2017	Lead	<0.001	0.015
Middle School	Faculty Caf� Sink	2/22/2017	Copper	0.184	1.3
Middle School	Choral Rm Fountain	2/22/2017	Lead	<0.001	0.015
Middle School	Choral Rm Fountain	2/22/2017	Copper	0.414	1.3
Middle School	Rm 204 Fountain	2/22/2017	Lead	<0.001	0.015
Middle School	Rm 204 Fountain	2/22/2017	Copper	0.184	1.3
Middle School	Rm 214 Fountain	2/22/2017	Lead	<0.001	0.015
Middle School	Rm 214 Fountain	2/22/2017	Copper	0.352	1.3
Middle School	Rm 245 Fountain	2/22/2017	Lead	<0.001	0.015
Middle School	Rm 245 Fountain	2/22/2017	Copper	0.325	1.3
Middle School	Rm 314 Fountain	2/22/2017	Lead	<0.001	0.015
Middle School	Rm 314 Fountain	2/22/2017	Copper	0.349	1.3
Middle School	3rd Flr Band Fountain	2/22/2017	Lead	<0.001	0.015
Middle School	3rd Flr Band Fountain	2/22/2017	Copper	0.760	1.3
Middle School	Rm 304 Fountain	2/22/2017	Lead	<0.001	0.015
Middle School	Rm 304 Fountain	2/22/2017	Copper	0.290	1.3
Connequen Elementary	Nurse's Office Foun Lft	2/23/2017	Lead	<0.001	0.015
Connequen Elementary	Nurse's Office Foun Lft	2/23/2017	Copper	0.555	1.3
Connequen Elementary	Nurse's Office Foun Rgt	2/23/2017	Lead	<0.001	0.015
Connequen Elementary	Nurse's Office Foun Rgt	2/23/2017	Copper	0.561	1.3
Connequen Elementary	Nurse's Office Sink	2/23/2017	Lead	<0.001	0.015
Connequen Elementary	Nurse's Office Sink	2/23/2017	Copper	0.348	1.3
Connequen Elementary	Gym/MP Fount Lft	2/23/2017	Lead	<0.001	0.015
Connequen Elementary	Gym/MP Fount Lft	2/23/2017	Copper	0.708	1.3
Connequen Elementary	Gym/MP Fount Rgt	2/23/2017	Lead	<0.001	0.015
Connequen Elementary	Gym/MP Fount Rgt	2/23/2017	Copper	0.596	1.3
Connequen Elementary	Food Service Sink	2/23/2017	Lead	<0.001	0.015
Connequen Elementary	Food Service Sink	2/23/2017	Copper	0.575	1.3
Connequen Elementary	Boy's RR Fount Lft	2/23/2017	Lead	<0.001	0.015
Connequen Elementary	Boy's RR Fount Lft	2/23/2017	Copper	0.421	1.3
Connequen Elementary	Boy's RR Fount Rgt	2/23/2017	Lead	<0.001	0.015
Connequen Elementary	Boy's RR Fount Rgt	2/23/2017	Copper	0.325	1.3
Connequen Elementary	Girl's RR Fount Lft	2/23/2017	Lead	<0.001	0.015
Connequen Elementary	Girl's RR Fount Lft	2/23/2017	Copper	0.467	1.3
Connequen Elementary	Girl's RR Fount Rgt	2/23/2017	Lead	<0.001	0.015
Connequen Elementary	Girl's RR Fount Rgt	2/23/2017	Copper	0.329	1.3
Connequen Elementary	Faculty Room Sink	2/23/2017	Lead	<0.001	0.015
Connequen Elementary	Faculty Room Sink	2/23/2017	Copper	0.438	1.3
Connequen Elementary	Rm 12 Fountain Lft	2/23/2017	Lead	<0.001	0.015
Connequen Elementary	Rm 12 Fountain Lft	2/23/2017	Copper	0.357	1.3
Connequen Elementary	Rm 12 Fountain Rgt	2/23/2017	Lead	<0.001	0.015
Connequen Elementary	Rm 12 Fountain Rgt	2/23/2017	Copper	0.349	1.3

Facility	Location	Sample Date	Parameter	Result (mg/L) AL is Highlighted	Above PaDEP AL Designation (mg/l)
Center Twp Elementary	Rm 47 Fountain Left	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Rm 47 Fountain Left	2/23/2017	Copper	0.218	1.3
Center Twp Elementary	Rm 47 Fountain Right	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Rm 47 Fountain Right	2/23/2017	Copper	0.233	1.3
Center Twp Elementary	Food Service Sink	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Food Service Sink	2/23/2017	Copper	0.272	1.3
Center Twp Elementary	Cafeteria Fountain	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Cafeteria Fountain	2/23/2017	Copper	0.335	1.3
Center Twp Elementary	MP Room Fountain Lft	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	MP Room Fountain Lft	2/23/2017	Copper	0.357	1.3
Center Twp Elementary	MP Room Fountain Rgt	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	MP Room Fountain Rgt	2/23/2017	Copper	0.434	1.3
Center Twp Elementary	Nurse's Office Sink	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Nurses Off Sink	2/23/2017	Copper	0.261	1.3
Center Twp Elementary	Principal Off Fount Lft	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Principal Off Fount Lft	2/23/2017	Copper	0.305	1.3
Center Twp Elementary	Principal Off Fount Rgt	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Principal Off Fount Rgt	2/23/2017	Copper	0.353	1.3
Center Twp Elementary	Faculty Lounge Sink	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Faculty Lounge Sink	2/23/2017	Copper	0.309	1.3
Center Twp Elementary	Rm 61 Fount Left	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Rm 61 Fount Left	2/23/2017	Copper	0.316	1.3
Center Twp Elementary	Rm 61 Fount Right	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Rm 61 Fount Right	2/23/2017	Copper	0.175	1.3
Center Twp Elementary	Rm 72 Fountain	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Rm 72 Fountain	2/23/2017	Copper	0.134	1.3
Center Twp Elementary	Rm 27 Fountain Left	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Rm 27 Fountain Left	2/23/2017	Copper	0.220	1.3
Center Twp Elementary	Rm 27 Fountain Right	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Rm 27 Fountain Right	2/23/2017	Copper	0.201	1.3
Center Twp Elementary	Rm 20 Fountain Left	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Rm 20 Fountain Left	2/23/2017	Copper	0.195	1.3
Center Twp Elementary	Rm 20 Fountain Right	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Rm 20 Fountain Right	2/23/2017	Copper	0.178	1.3
Center Twp Elementary	Rm 14 Sink	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Rm 14 Sink	2/23/2017	Copper	0.348	1.3
Center Twp Elementary	Rm 37 Fountain Left	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Rm 37 Fountain Left	2/23/2017	Copper	0.255	1.3
Center Twp Elementary	Rm 37 Fountain Right	2/23/2017	Lead	<0.001	0.015
Center Twp Elementary	Rm 37 Fountain Right	2/23/2017	Copper	0.208	1.3
McQuiston Elementary	Faculty RR	2/22/2017	Lead	<0.001	0.015
McQuiston Elementary	Faculty RR	2/22/2017	Copper	0.610	1.3
McQuiston Elementary	Fountain Door 8	2/22/2017	Lead	0.001	0.015
McQuiston Elementary	Fountain Door 8	2/22/2017	Copper	0.799	1.3
McQuiston Elementary	Conference Rm 1 Left	2/22/2017	Lead	<0.001	0.015
McQuiston Elementary	Conference Rm 1 Left	2/22/2017	Copper	0.424	1.3
McQuiston Elementary	Conference Rm 1 Right	2/22/2017	Lead	<0.001	0.015
McQuiston Elementary	Conference Rm 1 Right	2/22/2017	Copper	0.322	1.3
McQuiston Elementary	Nurse's Office Sink	2/22/2017	Lead	<0.001	0.015
McQuiston Elementary	Nurse's Office Sink	2/22/2017	Copper	0.331	1.3
McQuiston Elementary	Faculty Lounge	2/22/2017	Lead	<0.001	0.015
McQuiston Elementary	Faculty Lounge	2/22/2017	Copper	0.210	1.3

Facility	Location	Sample Date	Parameter	Result (mg/L) Above AL is Highlighted	PaDEP AL Designation (mg/l)
McQuiston Elementary	Gym Fountain Left	2/22/2017	Lead	<0.001	0.015
McQuiston Elementary	Gym Fountain Left	2/22/2017	Copper	0.354	1.3
McQuiston Elementary	Gym Fountain Right	2/22/2017	Lead	<0.001	0.015
McQuiston Elementary	Gym Fountain Right	2/22/2017	Copper	0.255	1.3
McQuiston Elementary	Rm 20 Fountain Left	2/22/2017	Lead	<0.001	0.015
McQuiston Elementary	Rm 20 Fountain Left	2/22/2017	Copper	0.322	1.3
McQuiston Elementary	Rm 20 Fountain Right	2/22/2017	Lead	<0.001	0.015
McQuiston Elementary	Rm 20 Fountain Right	2/22/2017	Copper	0.206	1.3
McQuiston Elementary	LS Room	2/22/2017	Lead	<0.001	0.015
McQuiston Elementary	LS Room	2/22/2017	Copper	0.811	1.3
McQuiston Elementary	Vocal Music	2/22/2017	Lead	<0.001	0.015
McQuiston Elementary	Vocal Music	2/22/2017	Copper	0.728	1.3
McQuiston Elementary	Café Fountain Right	2/22/2017	Lead	<0.001	0.015
McQuiston Elementary	Café Fountain Right	2/22/2017	Copper	0.481	1.3
McQuiston Elementary	Café Fountain Left	2/22/2017	Lead	<0.001	0.015
McQuiston Elementary	Café Fountain Left	2/22/2017	Copper	0.375	1.3
McQuiston Elementary	Food Service Sink	2/22/2017	Lead	<0.001	0.015
McQuiston Elementary	Food Service Sink	2/22/2017	Copper	0.372	1.3
Northwest Elementary	Rm 13 Fountain	2/23/2017	Lead	<0.001	0.015
Northwest Elementary	Rm 13 Fountain	2/23/2017	Copper	0.457	1.3
Northwest Elementary	Rm 32 Fountain	2/23/2017	Lead	<0.001	0.015
Northwest Elementary	Rm 32 Fountain	2/23/2017	Copper	0.198	1.3
Northwest Elementary	Nurse's Office Sink	2/23/2017	Lead	0.003	0.015
Northwest Elementary	Nurse's Office Sink	2/23/2017	Copper	0.232	1.3
Northwest Elementary	Faculty Work Rm Sink	2/23/2017	Lead	0.001	0.015
Northwest Elementary	Faculty Work Rm Sink	2/23/2017	Copper	0.259	1.3
Northwest Elementary	Custodial Office Fount	2/23/2017	Lead	<0.001	0.015
Northwest Elementary	Custodial Office Fount	2/23/2017	Copper	0.162	1.3
Northwest Elementary	Janitor Closet Sink	2/23/2017	Lead	<0.001	0.015
Northwest Elementary	Janitor Closet Sink	2/23/2017	Copper	0.180	1.3
Northwest Elementary	Food Service Fount Lft	2/23/2017	Lead	<0.001	0.015
Northwest Elementary	Food Service Fount Lft	2/23/2017	Copper	0.163	1.3
Northwest Elementary	Food Service Fount Rgt	2/23/2017	Lead	<0.001	0.015
Northwest Elementary	Food Service Fount Rgt	2/23/2017	Copper	0.191	1.3
Northwest Elementary	Food Service Sink	2/23/2017	Lead	<0.001	0.015
Northwest Elementary	Food Service Sink	2/23/2017	Copper	0.286	1.3
Administration Bldg	Admin Payroll Fount	3/2/2017	Lead	0.006	0.015
Administration Bldg	Admin Payroll Fount	3/2/2017	Copper	0.155	1.3
Administration Bldg	Admin Vault Sink	3/2/2017	Lead	<0.001	0.015
Administration Bldg	Admin Vault Sink	3/2/2017	Copper	0.188	1.3
Administration Bldg	Admin Lower Fount	3/2/2017	Lead	0.011	0.015
Administration Bldg	Admin Lower Fount	3/2/2017	Copper	0.175	1.3
Administration Bldg	Admin Vault Fount	3/2/2017	Lead	0.004	0.015
Administration Bldg	Admin Vault Fount	3/2/2017	Copper	0.190	1.3